

DOCUMENT 00 91 13
ADDENDUM NO. 4

Onslow Water and Sewer Authority
North Topsail Beach Booster Pump Station
WKD Project No. 20200435.00.WL

ADDENDUM NO. 4

October 31, 2023

BID DATE: November 2, 2023 at 2:00 p.m.

TO ALL BIDDERS:

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents dated September 18, 2023 and all previous Addenda.

Acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to do so may disqualify the Bidder.

Below are changes, additions, and/or clarifications to the bid documents for this project.

Specifications

No changes with this Addendum.

Drawings

No changes with this Addendum.

Clarifications

- Item 1: All galvanized steel items are specified in Specification Section 05 12 00 – Structural Steel Framing.
- Item 2: The coating required for the upper 20' of H-Piles on Plan Sheet S-302 shall be Hi-Mil Sher-Tar Coal Tar Epoxy.
- Item 3: Specific manufacturers for the ¾ ton hoist and trolley are not named in the contract documents.
- Item 4: Fiberglass door and frame specifications are indicated in Specification Section 08 22 00 – Fiberglass Doors and Frames.
- Item 5: The simplex pump station on the north side of Loggerhead Court is abandoned.
- Item 6: Specification Section 03 30 00 – Cast-In-Place Concrete (Andrew), Article 2.6 provides requirements for steel reinforcing bars. Rebar for steel reinforcement does not need to be epoxy coated.

Item 7: Requirements for precast concrete structures are listed in Specification Section 33 05 13 – Utility Manholes and Structures, Article 2.1 Precast Reinforced Manholes and Structures. Coatings for precast structures are not specified for this project.

Item 8: Coatings for water piping, including above-ground and vault piping, are listed in Specification Sections 33 11 00 – Water Utility Distribution Piping and 33 05 19 – Pressure Piping Joint Restraint. Coatings for the packaged pumping system piping are listed in Specification Section 33 32 20 – Factory Assembled Booster Pumping Station.


Item 9: Requirements for bolts for piping connections are listed in Specification Sections 33 11 00 – Water Utility Distribution Piping and 33 05 19 – Pressure Piping Joint Restraint.

Item 10: Welding of 4-inch stainless steel posts for elevated panel supports is acceptable to form the required length as indicated on the Drawings. Welded connections must comply with AWS D1.1.

Receipt of this Addendum must be acknowledged on Page 7 of your Bid Form.

Sincerely,

W. K. Dickson & Co., Inc.
N.C. License F-0374


T. Carter Hubbard, P.E.
Project Manager



Oct 31 2023 11:46 AM